

Water Testing Results - SHCS

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Gym Fountain	2006480-001	6/9/2020	3.37 ppb
Classroom 4 Faucet	2006480-002	6/9/2020	7.78 ppb
Classroom 14 Faucet	2006480-003	6/9/2020	2.85 ppb
Breezeway Fountain	2006480-004	6/9/2020	8.30 ppb
Classroom 10 Fountain	2006480-005	6/9/2020	8.09 ppb

ND = Non Detect - Lead level is below the set detection limits of 2 ppb