

Initial results per electronic radon testing device are listed below. Measurements are in Picocuries per liter of air (pCi/L). Action level is 4.0 pCi/L. More testing will take place in the Fall of 2020.

Radon testing results for December 2019

<u>Sodaville</u>	<u>Short Term</u>	<u>Long Term</u>
Library	1.02	1.08
Dahlgren	1.62	1.64
Dougherty	1.13	1.21
Beiris	0.91	0.91
Brennen	0.02	0.45
Lower Lab	1.35	1.40
McMahon	1.35	0.72
Kolling	0.70	0.51
Lower Mods	0.10	0.18
Upper Mods	0.29	0.45
Science/Gym	0.02	0.27

January 2020

<u>S. Main</u>	<u>Short Term</u>	<u>Long Term</u>
Nursery	0.59	0.75
Kinder	0.37	0.32
Morris	0.29	0.18
Pre-School	0.24	0.24
Office	0.56	0.78

March 2020

<u>Liberty</u>	<u>Short Term</u>	<u>Long Term</u>
Swanson	3.70	3.35
McDowell	2.51	2.29
Hill	1.86	2.32